Saline Water Treatment Plant - Equipment Status Report



Report Updated <u>08/16</u> /2021

Equipment/Process/Resource	Status	Timeline
High Service Pumps	Green	12 to 24 months

Comments:

Green - Engineering review of third High Serve Pump in progress.

Reverse Osmosis	Green	12 to 18 months
-----------------	-------	-----------------

Comments:

Green - Sixty (60) RO unit membranes replaced spring 2021; additional replacements planned FY23 as part of regular maintenance.

Electrical/Communications	Yellow	6 to 24 months
---------------------------	--------	----------------

Comments:

Green - One Variable Frequency Drive replaced spring 2021; second VFD and filters pending council action (target approval September 13th)

Yellow - Upgrading communication equipment/SCADA integration

Equipment/Process/Resource	Status	Timeline			
Building Maintenance	Yellow	6 to 12 months			
Comments:					
Yellow - Facility condition ass	essment and capital planning in	n progress			
Iron/Manganese Removal	Yellow	9 to 12 months			
Yellow - Woody overgrowth removed from infiltration basins; additional iron removal efforts to be bid winter 2021/2022. Yellow - Greensand media filter replacement to be bid (per FY22 Capital Improvement Plan); engineering review in progress.					
Water Quality	Green	Ongoing			
Comments:					
Prior month average daily hardness: July: 131 mg/l; June:126 mg/l Winter Hardness Target: 110 to 120 mg/l Summer Hardness Target: less than 160 mg/l Prior month average daily volume: July: 1.266 MGD; June: 1.275 MGD Last hydrant flush: May 2021 (city wide) Next planned flush: October 2021 (city wide) Annual Water Quality Report: https://tinyurl.com/fdc5azvj Additional Comments:					