

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Monitoring Requirements Not Met for the City of Saline

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During May 2013 we did not monitor for all of the chlorine residuals that were required and therefore cannot be sure of the quality of our drinking water during that time.

What should I do? There is nothing you need to do at this time. This is not an emergency.

The table below lists the contaminants for which we did not properly test during May 2013:

Contaminant	Required sampling frequency	Number of samples taken	Number of samples that should have been taken	Date samples were next taken
Chlorine	1 measurement per monthly sample	12	15	May 15, 2013

What happened? What is being done?

We are required to collect 10 samples each month and measure multiple constituents including chlorine residuals. We routinely collect 12 samples each month as an increased means of public health protection. In May 2013 we had to collect three additional samples due to a total coliform positive result in one of the twelve samples. When we collected the three additional samples, we failed to analyze those three samples for chlorine residual. The additional samples were tested and found to be coliform negative. The other 11 samples were all within MDEQ standards.

For more information, please contact Mr. Robert Scull at 734-429-4907 ext. 2324, or the Michigan Department of Environmental Quality at 517-780-7840.

Please share this information with all other people who drink this water, especially those who may not have received this notice directly. You can do this by posting this notice in a public place or distributing copies by hand or mail.


This notice is being sent to you by the City of Saline.

CERTIFICATION:

WSSN: 05900

I certify that this water supply has fully complied with the public notification regulations in the Michigan Safe Drinking Water Act, 1976 PA 399, as amended, and the administrative rules.

Signature:



Title:

Superintendent

Date Distributed:

10-1-13